

DISCHARGE MONITORING REPORT (DMR)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

NAME: KOOTENAI-PONDERAY SEWER DISTRICT**ADDRESS:** PO BOX 562
KOOTENAI, ID 83840**FACILITY:** KOOTENAI-PONDERAY SEWER DISTRICT - KOOTENAI-PC**LOCATION:** 511 WHISKEY JACK ROAD
SANDPOINT, ID 83864**ATTN:** TIM CLOSSON, OPERATIONS MGR

ID0021229	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
03/01/2014	03/31/2014

DMR Mailing ZIP CODE: 83840

MINOR

(SUBR 01)

WASTEWATER TO BOYER SLOUGH

External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	3	*****	deg C		Monthly	Recorder (auto)
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	*****	deg C		Monthly	Recorder (auto)
BOD, 5-day, 20 deg. C	SAMPLE MEASUREMENT	40	49.5	lb/d	*****	13.6	15	mg/L		Weekly	COMP-8
00310 1 0 Effluent Gross	PERMIT REQUIREMENT	86 MO AVG	129 WKLY AVG	lb/d	*****	30 MO AVG	45 WKLY AVG	mg/L		Weekly	COMP-8
BOD, 5-day, 20 deg. C	SAMPLE MEASUREMENT	*****	*****	*****	*****	217.4	*****	mg/L		Weekly	COMP-8
00310 G 0 Raw Sewage Influent	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	*****	mg/L		Weekly	COMP-8
pH	SAMPLE MEASUREMENT	*****	*****	*****	7.15	*****	7.4	SU		Weekdays	GRAB
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 MINIMUM	*****	9 MAXIMUM	SU		Weekdays	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	53.3	69.1	lb/d	*****	17.8	23	mg/L		Weekly	COMP-8
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	101 MO AVG	152 WKLY AVG	lb/d	*****	30 MO AVG	45 WKLY AVG	mg/L		Weekly	COMP-8
Solids, total suspended	SAMPLE MEASUREMENT	*****	*****	*****	*****	126	*****	mg/L		Weekly	COMP-8
00530 G 0 Raw Sewage Influent	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	*****	mg/L		Weekly	COMP-8
Nitrogen, ammonia total [as N]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	25.3	mg/L		Monthly	COMP-8
00610 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. DAILY MX	mg/L		Monthly	COMP-8

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Tanner Weisgram		TELEPHONE		DATE
Tim Closson/ Operations Manager		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		(208)263-0229		04/03/2014
TYPED OR PRINTED				AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

DISCHARGE MONITORING REPORT (DMR)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

NAME: KOOTENAI-PONDERAY SEWER DISTRICT**ADDRESS:** PO BOX 562
KOOTENAI, ID 83840**FACILITY:** KOOTENAI-PONDERAY SEWER DISTRICT - KOOTENAI-PC**LOCATION:** 511 WHISKEY JACK ROAD
SANDPOINT, ID 83864**ATTN:** TIM CLOSSON, OPERATIONS MGR

ID0021229	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
03/01/2014	03/31/2014

DMR Mailing ZIP CODE: 83840

MINOR

(SUBR 01)

WASTEWATER TO BOYER SLOUGH

External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Nitrogen, nitrite total [as N]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	.05	mg/L		Monthly	COMP-8
00615 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. DAILY MX	mg/L		Monthly	COMP-8
Nitrogen, nitrate total [as N]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	.233	mg/L		Monthly	COMP-8
00620 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. DAILY MX	mg/L		Monthly	COMP-8
Nitrogen, Kjeldahl, total [as N]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	30.2	mg/L		Monthly	COMP-8
00625 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. DAILY MX	mg/L		Monthly	COMP-8
Phosphorus, total [as P]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	4.95	mg/L		Monthly	COMP-8
00665 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. DAILY MX	mg/L		Monthly	COMP-8
E. coli, MTEC-MF	SAMPLE MEASUREMENT	*****	*****	*****	*****	3.71764	33	#/100mL		5 Times Every Month	GRAB
31648 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	126 MO GEO	406 INST MAX	#/100mL		5 Times Every Month	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	.4338	*****	MGD	*****	*****	*****	*****		Continuous	Recorder (auto)
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	*****	MGD	*****	*****	*****	*****		Continuous	Recorder (auto)
Chlorine, total residual	SAMPLE MEASUREMENT	*****	*****	*****	*****	<= .1	<= .1	mg/L		Weekdays	GRAB
50060 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	.1 MO AVG	.1 DAILY MX	mg/L		Weekdays	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Tanner Weisgram		TELEPHONE		DATE	
Tim Closson/ Operations Manager		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		(208)263-0229		04/03/2014	
TYPED OR PRINTED				AREA Code	NUMBER	MM/DD/YYYY	

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

DISCHARGE MONITORING REPORT (DMR)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

NAME: KOOTENAI-PONDERAY SEWER DISTRICT**ADDRESS:** PO BOX 562
KOOTENAI, ID 83840**FACILITY:** KOOTENAI-PONDERAY SEWER DISTRICT - KOOTENAI-PC**LOCATION:** 511 WHISKEY JACK ROAD
SANDPOINT, ID 83864**ATTN:** TIM CLOSSON, OPERATIONS MGR

ID0021229	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
03/01/2014	03/31/2014

DMR Mailing ZIP CODE: 83840

MINOR

(SUBR 01)

WASTEWATER TO BOYER SLOUGH

External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
BOD, 5-day, percent removal	SAMPLE MEASUREMENT	*****	*****	*****	94	*****	*****	%		Monthly	CALCTD
81010 K 0 Percent Removal	PERMIT REQUIREMENT	*****	*****	*****	85 MN % RMV	*****	*****	%		Monthly	CALCTD
Solids, suspended percent removal	SAMPLE MEASUREMENT	*****	*****	*****	86	*****	*****	%		Monthly	CALCTD
81011 K 0 Percent Removal	PERMIT REQUIREMENT	*****	*****	*****	85 MN % RMV	*****	*****	%		Monthly	CALCTD

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Tanner Weisgram	TELEPHONE	DATE
Tim Closson/ Operations Manager		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	(208)263-0229	04/03/2014
TYPED OR PRINTED			AREA Code NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

DISCHARGE MONITORING REPORT (DMR)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

NAME: KOOTENAI-PONDERAY SEWER DISTRICT**ADDRESS:** PO BOX 562
KOOTENAI, ID 83840**FACILITY:** KOOTENAI-PONDERAY SEWER DISTRICT - KOOTENAI-PC**LOCATION:** 511 WHISKEY JACK ROAD
SANDPOINT, ID 83864**ATTN:** TIM CLOSSON, OPERATIONS MGR

ID0021229	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
04/01/2014	04/30/2014

DMR Mailing ZIP CODE: 83840

MINOR

(SUBR 01)

WASTEWATER TO BOYER SLOUGH

External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	9.8	*****	deg C		Monthly	Recorder (auto)
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	*****	deg C		Monthly	Recorder (auto)
BOD, 5-day, 20 deg. C	SAMPLE MEASUREMENT	36.2	47.6	lb/d	*****	14.8	17.3	mg/L		Weekly	COMP-8
00310 1 0 Effluent Gross	PERMIT REQUIREMENT	86 MO AVG	129 WKLY AVG	lb/d	*****	30 MO AVG	45 WKLY AVG	mg/L		Weekly	COMP-8
BOD, 5-day, 20 deg. C	SAMPLE MEASUREMENT	*****	*****	*****	*****	270.8	*****	mg/L		Weekly	COMP-8
00310 G 0 Raw Sewage Influent	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	*****	mg/L		Weekly	COMP-8
pH	SAMPLE MEASUREMENT	*****	*****	*****	7.25	*****	7.4	SU		Weekdays	GRAB
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 MINIMUM	*****	9 MAXIMUM	SU		Weekdays	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	28.8	36.2	lb/d	*****	11.8	14	mg/L		Weekly	COMP-8
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	101 MO AVG	152 WKLY AVG	lb/d	*****	30 MO AVG	45 WKLY AVG	mg/L		Weekly	COMP-8
Solids, total suspended	SAMPLE MEASUREMENT	*****	*****	*****	*****	191	*****	mg/L		Weekly	COMP-8
00530 G 0 Raw Sewage Influent	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	*****	mg/L		Weekly	COMP-8
Nitrogen, ammonia total [as N]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	19.8	mg/L		Monthly	COMP-8
00610 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. DAILY MX	mg/L		Monthly	COMP-8

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Tanner Weisgram		TELEPHONE		DATE
Tim Closson/ Operations Manager		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		(208)263-0229		05/07/2014
TYPED OR PRINTED				AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

DISCHARGE MONITORING REPORT (DMR)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

NAME: KOOTENAI-PONDERAY SEWER DISTRICT**ADDRESS:** PO BOX 562
KOOTENAI, ID 83840**FACILITY:** KOOTENAI-PONDERAY SEWER DISTRICT - KOOTENAI-PC**LOCATION:** 511 WHISKEY JACK ROAD
SANDPOINT, ID 83864**ATTN:** TIM CLOSSON, OPERATIONS MGR

ID0021229	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
04/01/2014	04/30/2014

DMR Mailing ZIP CODE: 83840

MINOR

(SUBR 01)

WASTEWATER TO BOYER SLOUGH

External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Nitrogen, nitrite total [as N]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	.25	mg/L		Monthly	COMP-8
00615 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. DAILY MX	mg/L		Monthly	COMP-8
Nitrogen, nitrate total [as N]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	.154	mg/L		Monthly	COMP-8
00620 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. DAILY MX	mg/L		Monthly	COMP-8
Nitrogen, Kjeldahl, total [as N]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	22.4	mg/L		Monthly	COMP-8
00625 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. DAILY MX	mg/L		Monthly	COMP-8
Phosphorus, total [as P]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	3.54	mg/L		Monthly	COMP-8
00665 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. DAILY MX	mg/L		Monthly	COMP-8
E. coli, MTEC-MF	SAMPLE MEASUREMENT	*****	*****	*****	*****	2	2	#/100mL		5 Times Every Month	GRAB
31648 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	126 MO GEO	406 INST MAX	#/100mL		5 Times Every Month	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	.4566	*****	MGD	*****	*****	*****	*****		Continuous	Recorder (auto)
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	*****	MGD	*****	*****	*****	*****		Continuous	Recorder (auto)
Chlorine, total residual	SAMPLE MEASUREMENT	*****	*****	*****	*****	<= .1	<= .1	mg/L		Weekdays	GRAB
50060 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	.1 MO AVG	.1 DAILY MX	mg/L		Weekdays	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Tanner Weisgram		TELEPHONE		DATE
Tim Closson/ Operations Manager		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		(208)263-0229		05/07/2014
TYPED OR PRINTED				AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

DISCHARGE MONITORING REPORT (DMR)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

NAME: KOOTENAI-PONDERAY SEWER DISTRICT**ADDRESS:** PO BOX 562
KOOTENAI, ID 83840**FACILITY:** KOOTENAI-PONDERAY SEWER DISTRICT - KOOTENAI-PC**LOCATION:** 511 WHISKEY JACK ROAD
SANDPOINT, ID 83864**ATTN:** TIM CLOSSON, OPERATIONS MGR

ID0021229	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
04/01/2014	04/30/2014

DMR Mailing ZIP CODE: 83840

MINOR

(SUBR 01)

WASTEWATER TO BOYER SLOUGH

External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
BOD, 5-day, percent removal	SAMPLE MEASUREMENT	*****	*****	*****	95	*****	*****	%		Monthly	CALCTD
81010 K 0 Percent Removal	PERMIT REQUIREMENT	*****	*****	*****	85 MN % RMV	*****	*****	%		Monthly	CALCTD
Solids, suspended percent removal	SAMPLE MEASUREMENT	*****	*****	*****	94	*****	*****	%		Monthly	CALCTD
81011 K 0 Percent Removal	PERMIT REQUIREMENT	*****	*****	*****	85 MN % RMV	*****	*****	%		Monthly	CALCTD

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Tanner Weisgram	TELEPHONE	DATE
Tim Closson/ Operations Manager		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	(208)263-0229	05/07/2014
TYPED OR PRINTED			AREA Code NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

DISCHARGE MONITORING REPORT (DMR)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

NAME: KOOTENAI-PONDERAY SEWER DISTRICT**ADDRESS:** PO BOX 562
KOOTENAI, ID 83840**FACILITY:** KOOTENAI-PONDERAY SEWER DISTRICT - KOOTENAI-PC**LOCATION:** 511 WHISKEY JACK ROAD
SANDPOINT, ID 83864**ATTN:** TIM CLOSSON, OPERATIONS MGR

ID0021229	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
05/01/2014	05/31/2014

DMR Mailing ZIP CODE: 83840

MINOR

(SUBR 01)

WASTEWATER TO BOYER SLOUGH

External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	15.2	*****	deg C		Monthly	Recorder (auto)
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	*****	deg C		Monthly	Recorder (auto)
BOD, 5-day, 20 deg. C	SAMPLE MEASUREMENT	32.3	39.9	lb/d	*****	14.8	17.1	mg/L		Weekly	COMP-8
00310 1 0 Effluent Gross	PERMIT REQUIREMENT	86 MO AVG	129 WKLY AVG	lb/d	*****	30 MO AVG	45 WKLY AVG	mg/L		Weekly	COMP-8
BOD, 5-day, 20 deg. C	SAMPLE MEASUREMENT	*****	*****	*****	*****	243	*****	mg/L		Weekly	COMP-8
00310 G 0 Raw Sewage Influent	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	*****	mg/L		Weekly	COMP-8
pH	SAMPLE MEASUREMENT	*****	*****	*****	7.3	*****	7.5	SU		Weekdays	GRAB
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 MINIMUM	*****	9 MAXIMUM	SU		Weekdays	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	15.7	19.5	lb/d	*****	7.3	9	mg/L		Weekly	COMP-8
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	101 MO AVG	152 WKLY AVG	lb/d	*****	30 MO AVG	45 WKLY AVG	mg/L		Weekly	COMP-8
Solids, total suspended	SAMPLE MEASUREMENT	*****	*****	*****	*****	182.5	*****	mg/L		Weekly	COMP-8
00530 G 0 Raw Sewage Influent	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	*****	mg/L		Weekly	COMP-8
Nitrogen, ammonia total [as N]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	16	mg/L		Monthly	COMP-8
00610 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. DAILY MX	mg/L		Monthly	COMP-8

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Tanner Weisgram		TELEPHONE		DATE	
Tim Closson/ Operations Manager				(208)263-0229		06/04/2014	
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code	NUMBER	MM/DD/YYYY	

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

DISCHARGE MONITORING REPORT (DMR)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

NAME: KOOTENAI-PONDERAY SEWER DISTRICT**ADDRESS:** PO BOX 562
KOOTENAI, ID 83840**FACILITY:** KOOTENAI-PONDERAY SEWER DISTRICT - KOOTENAI-PC**LOCATION:** 511 WHISKEY JACK ROAD
SANDPOINT, ID 83864**ATTN:** TIM CLOSSON, OPERATIONS MGR

ID0021229	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
05/01/2014	05/31/2014

DMR Mailing ZIP CODE: 83840

MINOR

(SUBR 01)

WASTEWATER TO BOYER SLOUGH

External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Nitrogen, nitrite total [as N]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	.697	mg/L		Monthly	COMP-8
00615 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. DAILY MX	mg/L		Monthly	COMP-8
Nitrogen, nitrate total [as N]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	.236	mg/L		Monthly	COMP-8
00620 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. DAILY MX	mg/L		Monthly	COMP-8
Nitrogen, Kjeldahl, total [as N]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	19.4	mg/L		Monthly	COMP-8
00625 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. DAILY MX	mg/L		Monthly	COMP-8
Phosphorus, total [as P]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	3.22	mg/L		Monthly	COMP-8
00665 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. DAILY MX	mg/L		Monthly	COMP-8
E. coli, MTEC-MF	SAMPLE MEASUREMENT	*****	*****	*****	*****	2	2	#/100mL		5 Times Every Month	GRAB
31648 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	126 MO GEO	406 INST MAX	#/100mL		5 Times Every Month	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	.4218	*****	MGD	*****	*****	*****	*****		Continuous	Recorder (auto)
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	*****	MGD	*****	*****	*****	*****		Continuous	Recorder (auto)
Chlorine, total residual	SAMPLE MEASUREMENT	*****	*****	*****	*****	<= .1	<= .1	mg/L		Weekdays	GRAB
50060 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	.1 MO AVG	.1 DAILY MX	mg/L		Weekdays	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Tanner Weisgram		TELEPHONE		DATE
Tim Closson/ Operations Manager		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		(208)263-0229		06/04/2014
TYPED OR PRINTED				AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

DISCHARGE MONITORING REPORT (DMR)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

NAME: KOOTENAI-PONDERAY SEWER DISTRICT**ADDRESS:** PO BOX 562
KOOTENAI, ID 83840**FACILITY:** KOOTENAI-PONDERAY SEWER DISTRICT - KOOTENAI-PC**LOCATION:** 511 WHISKEY JACK ROAD
SANDPOINT, ID 83864**ATTN:** TIM CLOSSON, OPERATIONS MGR

ID0021229	001-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
05/01/2014	05/31/2014

DMR Mailing ZIP CODE: 83840

MINOR

(SUBR 01)

WASTEWATER TO BOYER SLOUGH

External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
BOD, 5-day, percent removal	SAMPLE MEASUREMENT	*****	*****	*****	94	*****	*****	%		Monthly	CALCTD
81010 K 0 Percent Removal	PERMIT REQUIREMENT	*****	*****	*****	85 MN % RMV	*****	*****	%		Monthly	CALCTD
Solids, suspended percent removal	SAMPLE MEASUREMENT	*****	*****	*****	96	*****	*****	%		Monthly	CALCTD
81011 K 0 Percent Removal	PERMIT REQUIREMENT	*****	*****	*****	85 MN % RMV	*****	*****	%		Monthly	CALCTD

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Tanner Weisgram	TELEPHONE	DATE
Tim Closson/ Operations Manager		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	(208)263-0229	06/04/2014
TYPED OR PRINTED			AREA Code NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

DISCHARGE MONITORING REPORT (DMR)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

NAME: KOOTENAI-PONDERAY SEWER DISTRICT**ADDRESS:** PO BOX 562
KOOTENAI, ID 83840**FACILITY:** KOOTENAI-PONDERAY SEWER DISTRICT - KOOTENAI-PC**LOCATION:** 511 WHISKEY JACK ROAD
SANDPOINT, ID 83864**ATTN:** TIM CLOSSON, OPERATIONS MGR

ID0021229	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
06/01/2014	06/30/2014

DMR Mailing ZIP CODE: 83840

MINOR

(SUBR 01)

WASTEWATER TO BOYER SLOUGH

External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	18.8	*****	deg C		Monthly	Recorder (auto)
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	*****	deg C		Monthly	Recorder (auto)
BOD, 5-day, 20 deg. C	SAMPLE MEASUREMENT	14.6	16.9	lb/d	*****	9.9	11.9	mg/L		Weekly	COMP-8
00310 1 0 Effluent Gross	PERMIT REQUIREMENT	86 MO AVG	129 WKLY AVG	lb/d	*****	30 MO AVG	45 WKLY AVG	mg/L		Weekly	COMP-8
BOD, 5-day, 20 deg. C	SAMPLE MEASUREMENT	*****	*****	*****	*****	365.5	*****	mg/L		Weekly	COMP-8
00310 G 0 Raw Sewage Influent	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	*****	mg/L		Weekly	COMP-8
pH	SAMPLE MEASUREMENT	*****	*****	*****	7	*****	7.25	SU		Weekdays	GRAB
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 MINIMUM	*****	9 MAXIMUM	SU		Weekdays	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	19.5	20.6	lb/d	*****	13	13	mg/L		Weekly	COMP-8
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	101 MO AVG	152 WKLY AVG	lb/d	*****	30 MO AVG	45 WKLY AVG	mg/L		Weekly	COMP-8
Solids, total suspended	SAMPLE MEASUREMENT	*****	*****	*****	*****	252	*****	mg/L		Weekly	COMP-8
00530 G 0 Raw Sewage Influent	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	*****	mg/L		Weekly	COMP-8
Nitrogen, ammonia total [as N]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	17.4	mg/L		Monthly	COMP-8
00610 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. DAILY MX	mg/L		Monthly	COMP-8

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Tanner Weisgram		TELEPHONE		DATE
Tim Closson/ Operations Manager		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		(208)263-0229		07/07/2014
TYPED OR PRINTED				AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

DISCHARGE MONITORING REPORT (DMR)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

NAME: KOOTENAI-PONDERAY SEWER DISTRICT**ADDRESS:** PO BOX 562
KOOTENAI, ID 83840**FACILITY:** KOOTENAI-PONDERAY SEWER DISTRICT - KOOTENAI-PC**LOCATION:** 511 WHISKEY JACK ROAD
SANDPOINT, ID 83864**ATTN:** TIM CLOSSON, OPERATIONS MGR

ID0021229	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
06/01/2014	06/30/2014

DMR Mailing ZIP CODE: 83840

MINOR

(SUBR 01)

WASTEWATER TO BOYER SLOUGH

External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Nitrogen, nitrite total [as N]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	4.04	mg/L		Monthly	COMP-8
00615 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. DAILY MX	mg/L		Monthly	COMP-8
Nitrogen, nitrate total [as N]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	.0144	mg/L		Monthly	COMP-8
00620 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. DAILY MX	mg/L		Monthly	COMP-8
Nitrogen, Kjeldahl, total [as N]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	24.4	mg/L		Monthly	COMP-8
00625 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. DAILY MX	mg/L		Monthly	COMP-8
Phosphorus, total [as P]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	4.15	mg/L		Monthly	COMP-8
00665 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. DAILY MX	mg/L		Monthly	COMP-8
E. coli, MTEC-MF	SAMPLE MEASUREMENT	*****	*****	*****	*****	2	2	#/100mL		5 Times Every Month	GRAB
31648 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	126 MO GEO	406 INST MAX	#/100mL		5 Times Every Month	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	.34	*****	MGD	*****	*****	*****	*****		Continuous	Recorder (auto)
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	*****	MGD	*****	*****	*****	*****		Continuous	Recorder (auto)
Chlorine, total residual	SAMPLE MEASUREMENT	*****	*****	*****	*****	<= .1	<= .1	mg/L		Weekdays	GRAB
50060 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	.1 MO AVG	.1 DAILY MX	mg/L		Weekdays	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Tanner Weisgram		TELEPHONE		DATE
Tim Closson/ Operations Manager		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		(208)263-0229		07/07/2014
TYPED OR PRINTED				AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

DISCHARGE MONITORING REPORT (DMR)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

NAME: KOOTENAI-PONDERAY SEWER DISTRICT**ADDRESS:** PO BOX 562
KOOTENAI, ID 83840**FACILITY:** KOOTENAI-PONDERAY SEWER DISTRICT - KOOTENAI-PC**LOCATION:** 511 WHISKEY JACK ROAD
SANDPOINT, ID 83864**ATTN:** TIM CLOSSON, OPERATIONS MGR

ID0021229	001-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
06/01/2014	06/30/2014

DMR Mailing ZIP CODE: 83840

MINOR

(SUBR 01)

WASTEWATER TO BOYER SLOUGH

External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
BOD, 5-day, percent removal	SAMPLE MEASUREMENT	*****	*****	*****	97	*****	*****	%		Monthly	CALCTD
81010 K 0 Percent Removal	PERMIT REQUIREMENT	*****	*****	*****	85 MN % RMV	*****	*****	%		Monthly	CALCTD
Solids, suspended percent removal	SAMPLE MEASUREMENT	*****	*****	*****	95	*****	*****	%		Monthly	CALCTD
81011 K 0 Percent Removal	PERMIT REQUIREMENT	*****	*****	*****	85 MN % RMV	*****	*****	%		Monthly	CALCTD

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Tanner Weisgram	TELEPHONE	DATE
Tim Closson/ Operations Manager		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	(208)263-0229	07/07/2014
TYPED OR PRINTED			AREA Code NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

DISCHARGE MONITORING REPORT (DMR)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

NAME: KOOTENAI-PONDERAY SEWER DISTRICT**ADDRESS:** PO BOX 562
KOOTENAI, ID 83840**FACILITY:** KOOTENAI-PONDERAY SEWER DISTRICT - KOOTENAI-PC**LOCATION:** 511 WHISKEY JACK ROAD
SANDPOINT, ID 83864**ATTN:** TIM CLOSSON, OPERATIONS MGR

ID0021229	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
07/01/2014	07/31/2014

DMR Mailing ZIP CODE: 83840

MINOR

(SUBR 01)

WASTEWATER TO BOYER SLOUGH

External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	19.9	*****	deg C		Monthly	Recorder (auto)
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	*****	deg C		Monthly	Recorder (auto)
BOD, 5-day, 20 deg. C	SAMPLE MEASUREMENT	11.7	11.7	lb/d	*****	10	10	mg/L		Weekly	COMP-8
00310 1 0 Effluent Gross	PERMIT REQUIREMENT	86 MO AVG	129 WKLY AVG	lb/d	*****	30 MO AVG	45 WKLY AVG	mg/L		Weekly	COMP-8
BOD, 5-day, 20 deg. C	SAMPLE MEASUREMENT	*****	*****	*****	*****	300	*****	mg/L		Weekly	COMP-8
00310 G 0 Raw Sewage Influent	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	*****	mg/L		Weekly	COMP-8
pH	SAMPLE MEASUREMENT	*****	*****	*****	7	*****	7.25	SU		Weekdays	GRAB
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 MINIMUM	*****	9 MAXIMUM	SU		Weekdays	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	12.8	12.8	lb/d	*****	11	11	mg/L		Weekly	COMP-8
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	101 MO AVG	152 WKLY AVG	lb/d	*****	30 MO AVG	45 WKLY AVG	mg/L		Weekly	COMP-8
Solids, total suspended	SAMPLE MEASUREMENT	*****	*****	*****	*****	176	*****	mg/L		Weekly	COMP-8
00530 G 0 Raw Sewage Influent	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	*****	mg/L		Weekly	COMP-8
Nitrogen, ammonia total [as N]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	.199	mg/L		Monthly	COMP-8
00610 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. DAILY MX	mg/L		Monthly	COMP-8

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Tanner Weisgram		TELEPHONE		DATE
(208)263-0229				08/07/2014		
Tanner Weisgram/ Operations Manager		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code	NUMBER	MM/DD/YYYY
TYPED OR PRINTED						

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

DISCHARGE MONITORING REPORT (DMR)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

NAME: KOOTENAI-PONDERAY SEWER DISTRICT**ADDRESS:** PO BOX 562
KOOTENAI, ID 83840**FACILITY:** KOOTENAI-PONDERAY SEWER DISTRICT - KOOTENAI-PC**LOCATION:** 511 WHISKEY JACK ROAD
SANDPOINT, ID 83864**ATTN:** TIM CLOSSON, OPERATIONS MGR

ID0021229	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
07/01/2014	07/31/2014

DMR Mailing ZIP CODE: 83840

MINOR

(SUBR 01)

WASTEWATER TO BOYER SLOUGH

External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Nitrogen, nitrite total [as N]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	.16	mg/L		Monthly	COMP-8
00615 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. DAILY MX	mg/L		Monthly	COMP-8
Nitrogen, nitrate total [as N]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	16.5	mg/L		Monthly	COMP-8
00620 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. DAILY MX	mg/L		Monthly	COMP-8
Nitrogen, Kjeldahl, total [as N]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	4.24	mg/L		Monthly	COMP-8
00625 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. DAILY MX	mg/L		Monthly	COMP-8
Phosphorus, total [as P]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	3.89	mg/L		Monthly	COMP-8
00665 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. DAILY MX	mg/L		Monthly	COMP-8
E. coli, MTEC-MF	SAMPLE MEASUREMENT	*****	*****	*****	*****	3.16	5	#/100mL		5 Times Every Month	GRAB
31648 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	126 MO GEO	406 INST MAX	#/100mL		5 Times Every Month	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	.2624	*****	MGD	*****	*****	*****	*****		Continuous	Recorder (auto)
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	*****	MGD	*****	*****	*****	*****		Continuous	Recorder (auto)
Chlorine, total residual	SAMPLE MEASUREMENT	*****	*****	*****	*****	<= .1	<= .1	mg/L		Weekdays	GRAB
50060 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	.1 MO AVG	.1 DAILY MX	mg/L		Weekdays	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Tanner Weisgram		TELEPHONE		DATE	
Tanner Weisgram/ Operations Manager		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		(208)263-0229		08/07/2014	
TYPED OR PRINTED				AREA Code	NUMBER	MM/DD/YYYY	

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

DISCHARGE MONITORING REPORT (DMR)

OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

NAME: KOOTENAI-PONDERAY SEWER DISTRICT**ADDRESS:** PO BOX 562
KOOTENAI, ID 83840**FACILITY:** KOOTENAI-PONDERAY SEWER DISTRICT - KOOTENAI-PC**LOCATION:** 511 WHISKEY JACK ROAD
SANDPOINT, ID 83864**ATTN:** TIM CLOSSON, OPERATIONS MGR

ID0021229	001-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
07/01/2014	07/31/2014

DMR Mailing ZIP CODE: 83840

MINOR

(SUBR 01)

WASTEWATER TO BOYER SLOUGH

External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
BOD, 5-day, percent removal	SAMPLE MEASUREMENT	*****	*****	*****	97	*****	*****	%		Monthly	CALCTD
81010 K 0 Percent Removal	PERMIT REQUIREMENT	*****	*****	*****	85 MN % RMV	*****	*****	%		Monthly	CALCTD
Solids, suspended percent removal	SAMPLE MEASUREMENT	*****	*****	*****	94	*****	*****	%		Monthly	CALCTD
81011 K 0 Percent Removal	PERMIT REQUIREMENT	*****	*****	*****	85 MN % RMV	*****	*****	%		Monthly	CALCTD

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Tanner Weisgram		TELEPHONE	DATE
Tanner Weisgram/ Operations Manager		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		(208)263-0229	08/07/2014
TYPED OR PRINTED				AREA Code	NUMBER

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

DISCHARGE MONITORING REPORT (DMR)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

NAME: KOOTENAI-PONDERAY SEWER DISTRICT**ADDRESS:** PO BOX 562
KOOTENAI, ID 83840**FACILITY:** KOOTENAI-PONDERAY SEWER DISTRICT - KOOTENAI-PC**LOCATION:** 511 WHISKEY JACK ROAD
SANDPOINT, ID 83864**ATTN:** TIM CLOSSON, OPERATIONS MGR

ID0021229	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
08/01/2014	08/31/2014

DMR Mailing ZIP CODE: 83840

MINOR

(SUBR 01)

WASTEWATER TO BOYER SLOUGH

External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	22.3	*****	deg C		Monthly	Recorder (auto)
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	*****	deg C		Monthly	Recorder (auto)
BOD, 5-day, 20 deg. C	SAMPLE MEASUREMENT	18.5	28.6	lb/d	*****	13.2	20.2	mg/L		Weekly	COMP-8
00310 1 0 Effluent Gross	PERMIT REQUIREMENT	86 MO AVG	129 WKLY AVG	lb/d	*****	30 MO AVG	45 WKLY AVG	mg/L		Weekly	COMP-8
BOD, 5-day, 20 deg. C	SAMPLE MEASUREMENT	*****	*****	*****	*****	394.5	*****	mg/L		Weekly	COMP-8
00310 G 0 Raw Sewage Influent	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	*****	mg/L		Weekly	COMP-8
pH	SAMPLE MEASUREMENT	*****	*****	*****	7.1	*****	7.6	SU		Weekdays	GRAB
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 MINIMUM	*****	9 MAXIMUM	SU		Weekdays	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	13.2	18.4	lb/d	*****	9.5	13	mg/L		Weekly	COMP-8
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	101 MO AVG	152 WKLY AVG	lb/d	*****	30 MO AVG	45 WKLY AVG	mg/L		Weekly	COMP-8
Solids, total suspended	SAMPLE MEASUREMENT	*****	*****	*****	*****	238.5	*****	mg/L		Weekly	COMP-8
00530 G 0 Raw Sewage Influent	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	*****	mg/L		Weekly	COMP-8
Nitrogen, ammonia total [as N]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	1	mg/L		Monthly	COMP-8
00610 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. DAILY MX	mg/L		Monthly	COMP-8

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Tanner Weisgram		TELEPHONE		DATE	
Tanner Weisgram/ Operations Manager		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		(208)263-0229		09/05/2014	
TYPED OR PRINTED				AREA Code	NUMBER	MM/DD/YYYY	

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

DISCHARGE MONITORING REPORT (DMR)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

NAME: KOOTENAI-PONDERAY SEWER DISTRICT**ADDRESS:** PO BOX 562
KOOTENAI, ID 83840**FACILITY:** KOOTENAI-PONDERAY SEWER DISTRICT - KOOTENAI-PC**LOCATION:** 511 WHISKEY JACK ROAD
SANDPOINT, ID 83864**ATTN:** TIM CLOSSON, OPERATIONS MGR

ID0021229	001-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
08/01/2014	08/31/2014

DMR Mailing ZIP CODE: 83840

MINOR

(SUBR 01)

WASTEWATER TO BOYER SLOUGH

External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Nitrogen, nitrite total [as N]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	1.83	mg/L		Monthly	COMP-8
00615 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. DAILY MX	mg/L		Monthly	COMP-8
Nitrogen, nitrate total [as N]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	7.64	mg/L		Monthly	COMP-8
00620 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. DAILY MX	mg/L		Monthly	COMP-8
Nitrogen, Kjeldahl, total [as N]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	4.74	mg/L		Monthly	COMP-8
00625 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. DAILY MX	mg/L		Monthly	COMP-8
Phosphorus, total [as P]	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	7.06	mg/L		Monthly	COMP-8
00665 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. DAILY MX	mg/L		Monthly	COMP-8
E. coli, MTEC-MF	SAMPLE MEASUREMENT	*****	*****	*****	*****	2.71442	5	#/100mL		5 Times Every Month	GRAB
31648 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	126 MO GEO	406 INST MAX	#/100mL		5 Times Every Month	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	.3893	*****	MGD	*****	*****	*****	*****		Continuous	Recorder (auto)
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	*****	MGD	*****	*****	*****	*****		Continuous	Recorder (auto)
Chlorine, total residual	SAMPLE MEASUREMENT	*****	*****	*****	*****	<= .1	<= .1	mg/L		Weekdays	GRAB
50060 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	.1 MO AVG	.1 DAILY MX	mg/L		Weekdays	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Tanner Weisgram		TELEPHONE		DATE	
Tanner Weisgram/ Operations Manager		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		(208)263-0229		09/05/2014	
TYPED OR PRINTED				AREA Code	NUMBER	MM/DD/YYYY	

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

DISCHARGE MONITORING REPORT (DMR)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

NAME: KOOTENAI-PONDERAY SEWER DISTRICT**ADDRESS:** PO BOX 562
KOOTENAI, ID 83840**FACILITY:** KOOTENAI-PONDERAY SEWER DISTRICT - KOOTENAI-PC**LOCATION:** 511 WHISKEY JACK ROAD
SANDPOINT, ID 83864**ATTN:** TIM CLOSSON, OPERATIONS MGR

ID0021229	001-A
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
08/01/2014	08/31/2014

DMR Mailing ZIP CODE: 83840

MINOR

(SUBR 01)

WASTEWATER TO BOYER SLOUGH

External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
BOD, 5-day, percent removal	SAMPLE MEASUREMENT	*****	*****	*****	97	*****	*****	%		Monthly	CALCTD
81010 K 0 Percent Removal	PERMIT REQUIREMENT	*****	*****	*****	85 MN % RMV	*****	*****	%		Monthly	CALCTD
Solids, suspended percent removal	SAMPLE MEASUREMENT	*****	*****	*****	96	*****	*****	%		Monthly	CALCTD
81011 K 0 Percent Removal	PERMIT REQUIREMENT	*****	*****	*****	85 MN % RMV	*****	*****	%		Monthly	CALCTD

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Tanner Weisgram		TELEPHONE	DATE
Tanner Weisgram/ Operations Manager		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		(208)263-0229	09/05/2014
TYPED OR PRINTED				AREA Code	NUMBER

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)